

PHAP25-00021

Date: July 24, 2025

Application Type: Certificate of Appropriateness

Property Owner: Martha Jordan **Representative:** Karla Terrazas

Legal Description: 83 Government Hill 20 to 22 (12375 SQ FT), City of El Paso, El Paso

County, Texas

Historic District: Austin Terrace Location: 4410 Leeds Avenue

Representative District: #2

Existing Zoning: R-4/H (Residential/Historic)

Year Built: 1951

Historic Status: Non-Contributing

Request: Certificate of Appropriateness for installation of new windows

Application Filed: 6/12/2025 **45 Day Expiration:** 7/27/2025



GENERAL INFORMATION:

The applicant seeks approval for:

Certificate of Appropriateness for installation of new windows

STAFF RECOMMENDATION:

The Historic Preservation Office recommends APPROVAL WITH A MODIFICATION of the proposed scope of work based on the following recommendations:

The Design Guidelines for El Paso's Historic Districts, Sites, and Properties recommend the following:

- Doors and windows are considered important character-defining features because of significant detailing. When windows are involved in the construction process it is recommended to repair rather than replace. In many cases this will entail only the replacement of a broken sash cord, new weather stripping, removing old paint and repainting.
- Retain and preserve the pattern, arrangement, and dimensions of door and window openings on principal elevations. Often the placement of doors and windows is an indicator of a particular architectural style, and therefore contributes to the building's significance. Doors and windows for new construction and additions should be compatible in proportion, location, shape, pattern, size, and details to existing units.
- Retain and preserve original doors and windows, including such elements as sash, glass, sills, lintels, casings, muntins, trim, frames, thresholds, hardware and shutters. If repair of an original window or door element is necessary, repair only the deteriorated element to match the original in size, composition, material, dimension, and detail by patching, splicing, consolidating, or otherwise reinforcing the deteriorated section. The removal of historic materials should be avoided.
- When repair is not feasible, door and window products will be reviewed on an individual basis using the following criteria:
 - a. Architectural and historical compatibility
 - b. Comparison to original profile
 - c. Level of significance of original doors and windows to the architectural style of the building.
 - d. Three dimensional exterior applied muntins that simulate or match the original muntins may be approved. Single dimension interior applied muntins are not appropriate.

The Secretary of the Interior's Standards for Rehabilitation recommend the following:


- The historic character of a property shall be retained and preserved. The removal
 of historic materials or alteration of features and spaces that characterize a
 property shall be avoided.
- New additions, exterior alterations, or related new construction will not destroy
 historic materials, features, and spatial relationships that characterize the property.
 The new work will be differentiated from the old and will be compatible with the
 historic materials, features, size, scale and proportion, and massing to protect the
 integrity of the property and its environment.

The modification is that the new windows match the existing or historic windows.

AERIAL MAP



EXISTING WINDOW TYPE



#1

external Cirids

PROPOSED WINDOW TYPE

Sales Person:



Customer Acknowledgement Quote Date Date Ordered

Quote Not Ordered

Dealer Name:

Order Notes:

765430 WINDOW WORLD OF SW TX LLC-005-765430

Bill To:

WINDOW WORLD OF SWITX LLC

4800 N MESA

EL PASO, TX 79912

Ship To:

WINDOW WORLD OF SW TX LLC

4580 DONIPHAN

EL PASO, TX 79922

Delivery Notes:

Phone: (915) 533-8227 Fax:


Quote Name:

Project Name:

Jordan Martha

Jordan Martha

BANK QUOTE # THE PROPERTY OF T	BUSH ALL	STATUS	Parameter Downson and Downson
4078973	No		195-11979
1 1 66.25	"X 59.875" 127	Description of	



3A03-Mezzo XOX 66 1/4 x 59 7/8 Frame Width = 66.25, Frame Height = 59.875, Sash Split = 1/4 - 1/2 - 1/4 Option Level = Good, Operation / Venting = XOX Frame Option = Stucco, Steel Reinforcement Frame Color = White, Exterior Finish = No Exterior Finish ClimaTech Elite Extreme, Double Strength, Tempered Lock Height = Standard Lock Height Standard Screen U-Factor = 0.29, CR = 59, SHGC = 0.14, VT = 0.29, CPD = ASO-A-90-59926-00001 Foom Wrap, Net Overall


external Grids

Commenty Room

Sliver AAMA Label ONLY

Line Item Notes:

F DIN 1



[The low# Oly swidth a Helphi Still | Description | 72.75" X 73.5"

> 3A04-Mezzo Picture 72 3/4 x 73 1/2 Frame Width = 72.75, Frame Height = 73.5
> Option Level = Good, Operation / Venting = Picture
> Frame Option = Standard Block Frame, Composite Reinforcement Frame Color = White, Exterior Finish = No Exterior Finish ClimaTech Elite Plus Extreme, Double Strength, Tempered U-Factor = 0.27, CR = 61, SHGC = 0.15, VT = 0.31, CPD = ASO-A-91-15416-00001

Header Expander, Foam Wrap, Net Overall

Line Item Notes:

S. S. Comment / Room |

FDIN 2

40